

Below is a detail of item (s) required for subjected tender
Complete Tender documents have not been uploaded or emailed
as it is mandatory to visit the CUI-Lahore Campus (Works
Department-Sub Engineer Electrical) during office hours for the
inspection of Sample (s) / discussion and afterwards Tender
documents shall be issued.

Subject: Gas Cylinders for Air Conditioners of CUI-Lahore Campus

Case # 3115, Opening Date October 01, 2020 (1130Hrs) Tender No: CUI-LHR-TN-13-19-1416

Sr. #	Item Name & Specification	Qty.		Quoted Model / Brand	Unit Price (Rs.)	Total Amount (Rs.)
	<u>Turnkey Basis</u>					
1	<u>Gas Cylinder R-22 (Genuine)</u> , non refillable cylinder, having excellent cooling performance must be charge and working pressure 50 PSI to 55 PSI, Gas weight 13.6 KG, Genetron / Honywell USA or equivalent <i><u>Note: Copy of the Genuine Product is not acceptable</u></i>	40	Nos.			
2	<u>Gas Cylinder R-410a (Genuine)</u> , non refillable cylinder, having excellent cooling performance must be charged and working pressure 120 PSI to 130 PSI, Gas weight 11.3 KG, Genetron / Honywell USA or equivalent <i><u>Note: Copy of the Genuine Product is not acceptable</u></i>	10	Nos.			
3	<u>Gas Cylinder R-134 (Genuine)</u> , non refillable cylinder, having excellent cooling performance, weight 13.6 KG, Genetron / Honywell USA or equivalent <i><u>Note: Copy of the Genuine Product is not acceptable</u></i>	02	Nos.			

Please feel free to contact in case of any query;

Purchase Section
COMSATS University
Lahore Campus
042-111-001-007 ext 875